

---

August 23, 2024

Mr. Jacob Reiner  
Miami R-I Township School District  
34520 North Highway 41  
Miami, MO 65344

**RE: Drinking Water Resampling – Miami Township School District**  
34520 North Highway 41, Miami, MO 65344  
**Project Number: 924276**

Mr. Reiner,

OCCU-TEC, Inc. (OCCU-TEC) is pleased to present the following report for post-remediation drinking water sampling completed on recently replaced sources at the Miami R-1 Township School District (MTSD) in Miami, Missouri. OCCU-TEC completed sampling of sources that previously contained concentrations of lead above 5.0 parts per billion (ppb) and where fixtures had been subsequently replaced. Drinking water sampling was completed in accordance with the requirements set forth in Missouri Senate Bill #681/662 known as the “Get the Lead Out of School Drinking Water Act”.

### **METHODOLOGY**

On August 8<sup>th</sup>, 2024, Mr. Justin Henderson of OCCU-TEC completed testing of four (4) sources throughout the MTSD. Samples were collected as ‘First Draw’ samples after the fixtures had remained unused for a minimum period of 8 hours. Samples were collected in dedicated 250 milliliter laboratory-provided plastic sample containers. Sample location information and photographic documentation are noted in the attached table.

Samples were shipped to Teklab, Inc. (Teklab) of Collinsville, Illinois for analysis using EPA method 200.8. Teklab is approved for sample analysis by the Missouri Department of Natural Resources (MDNR) under certification number 00930. A copy of the laboratory analytical results and Chain of Custody documentation are attached to this report.

## RESULTS

Samples results were compared to the regulatory limit of 5 parts per billion (ppb) outlined in Missouri Senate Bill 681/662. Of the samples collected, one (1) of the four (4) contained lead concentrations at or above 5 ppb. Below is a list of samples collected and analytical results.

| Sample ID  | Location              | Type                   | Result (ug/L) |
|------------|-----------------------|------------------------|---------------|
| 164-MTS-05 | Art, Classroom 8      | Classroom Sink         | 3.6           |
| 164-MTS-10 | Kitchen               | Kitchen Sprayer Faucet | <1.0          |
| 164-MTS-12 | South Girls' Restroom | Restroom Sink          | 4.0           |
| 164-MTS-13 | South Girls' Restroom | Restroom Sink          | 5.3           |

Based on the current use of the sources, Miami placed signage on the sources to prevent use of water for drinking purposes. Photographs are attached to this document

## RECOMMENDATIONS

The following recommendations are in accordance with Senate Bill 681/662:

In accordance with the requirements set forth in Missouri Bill 681/662, fixtures exhibiting lead concentrations above 5 ppb must be remediated by replacement of lead-containing pipes, solder, fittings or fixtures with lead-free components, or the school shall install filtration at each point where water enters the building until such time as the source can be remediated. If installing a filter is not feasible, the school shall provide purified water at each outlet inventoried.

Additionally, any water coolers or drinking water outlets identified by the United States Environmental Protection Agency (EPA) as not being lead-free under the federal Lead Contamination Control Act of 1988 shall be replaced unless the unit has been tested and determined to have lead results under 5 ppb.

Within two weeks after receiving test results, the school shall make all testing results and any lead remediation plans available on the school's website. The school shall notify parents and staff via written notification within seven (7) business days after receiving test results exceeding 5 ppb. The notification shall include the following:

- Test results and a summary explaining the results.
- A description of any remedial steps taken.
- A description of the general health effects of lead contamination and community specific resources.
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.

For fixtures exhibiting results above 5 ppb, follow up random “Flush” sampling shall be conducted annually on at least 25 percent of the remediated outlets until all outlets have been remediated. Drinking water sampling shall be conducted annually and annual drinking water test results shall be submitted by the district to the Department of Health and Senior Services (MDHSS).

**LIMITATIONS**

OCCU-TEC did not complete remediation of the sources sampled and cannot verify the completeness of remediation.

**SIGNATURE(S)**

OCCU-TEC appreciates the opportunity to provide the above referenced consulting services to MTSD. If you have any questions regarding the contents of this report, please contact us at (816) 231-5580.

Respectfully,



Kevin Heriford  
Director EH&S Dept.



Jeff Smith  
Senior Project Manager(QA/QC)

**ATTACHMENTS**

Photographic Documentation

Laboratory Analytical Results and COC Documentation



Signage placed adjacent to 164-MTS-12 and 164-MTS-13

August 19, 2024

Justin Arnold  
Occu-Tec  
2604 NE Industrial Drive  
Suite 230  
North Kansas City, MO 64117  
TEL: (816) 810-3276  
FAX:



|           |              |
|-----------|--------------|
| Illinois  | 100226       |
| Illinois  | 1004652024-2 |
| Kansas    | E-10374      |
| Louisiana | 05002        |
| Louisiana | 05003        |
| Oklahoma  | 9978         |

**RE: 924276 MTS**

**WorkOrder: 24080975**

Dear Justin Arnold:

TEKLAB, INC received 4 samples on 8/10/2024 1:27:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley  
Project Manager  
(618)344-1004 ex 44  
[patrickriley@teklabinc.com](mailto:patrickriley@teklabinc.com)



## Report Contents

<http://www.teklabinc.com/>

---

**Client:** Occu-Tec

**Work Order:** 24080975

**Client Project:** 924276 MTS

**Report Date:** 19-Aug-24

---

**This reporting package includes the following:**

|                      |          |
|----------------------|----------|
| Cover Letter         | 1        |
| Report Contents      | 2        |
| Definitions          | 3        |
| Case Narrative       | 5        |
| Accreditations       | 6        |
| Laboratory Results   | 7        |
| Receiving Check List | 8        |
| Chain of Custody     | Appended |

Client: Occu-Tec

Work Order: 24080975

Client Project: 924276 MTS

Report Date: 19-Aug-24

### Abbr Definition

\* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count ( > 200 CFU )

**Client:** Occu-Tec

**Work Order:** 24080975

**Client Project:** 924276 MTS

**Report Date:** 19-Aug-24

---

### Qualifiers

- # - Unknown hydrocarbon
- C - RL shown is a Client Requested Quantitation Limit
- H - Holding times exceeded
- J - Analyte detected below quantitation limits
- ND - Not Detected at the Reporting Limit
- S - Spike Recovery outside recovery limits
- X - Value exceeds Maximum Contaminant Level
- B - Analyte detected in associated Method Blank
- E - Value above quantitation range
- I - Associated internal standard was outside method criteria
- M - Manual Integration used to determine area response
- R - RPD outside accepted recovery limits
- T - TIC(Tentatively identified compound)



Client: Occu-Tec

Work Order: 24080975

Client Project: 924276 MTS

Report Date: 19-Aug-24

Cooler Receipt Temp: N/A °C

---

**Locations**

---

**Collinsville**

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425

**Phone** (618) 344-1004

**Fax** (618) 344-1005

**Email** jhriley@teklabinc.com

---

**Collinsville Air**

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425

**Phone** (618) 344-1004

**Fax** (618) 344-1005

**Email** EHurley@teklabinc.com

---

**Springfield**

**Address** 3920 Pintail Dr  
Springfield, IL 62711-9415

**Phone** (217) 698-1004

**Fax** (217) 698-1005

**Email** KKlostermann@teklabinc.com

---

**Chicago**

**Address** 1319 Butterfield Rd.  
Downers Grove, IL 60515

**Phone** (630) 324-6855

**Fax**

**Email** arenner@teklabinc.com

---

**Kansas City**

**Address** 8421 Nieman Road  
Lenexa, KS 66214

**Phone** (913) 541-1998

**Fax** (913) 541-1998

**Email** jhriley@teklabinc.com



## Accreditations

<http://www.teklabinc.com/>

Client: Occu-Tec

Work Order: 24080975

Client Project: 924276 MTS

Report Date: 19-Aug-24

| State       | Dept | Cert #       | NELAP | Exp Date   | Lab          |
|-------------|------|--------------|-------|------------|--------------|
| Illinois    | IEPA | 100226       | NELAP | 1/31/2025  | Collinsville |
| Illinois    | IEPA | 1004652024-2 | NELAP | 4/30/2025  | Collinsville |
| Kansas      | KDHE | E-10374      | NELAP | 4/30/2025  | Collinsville |
| Louisiana   | LDEQ | 05002        | NELAP | 6/30/2025  | Collinsville |
| Louisiana   | LDEQ | 05003        | NELAP | 6/30/2025  | Collinsville |
| Oklahoma    | ODEQ | 9978         | NELAP | 8/31/2024  | Collinsville |
| Arkansas    | ADEQ | 88-0966      |       | 3/14/2025  | Collinsville |
| Illinois    | IDPH | 17584        |       | 5/31/2025  | Collinsville |
| Iowa        | IDNR | 430          |       | 6/1/2026   | Collinsville |
| Kentucky    | UST  | 0073         |       | 1/31/2025  | Collinsville |
| Mississippi | MSDH |              |       | 4/30/2025  | Collinsville |
| Missouri    | MDNR | 930          |       | 1/31/2025  | Collinsville |
| Missouri    | MDNR | 00930        |       | 10/31/2026 | Collinsville |



## Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec

Work Order: 24080975

Client Project: 924276 MTS

Report Date: 19-Aug-24

Matrix: DRINKING WATER

| Sample ID   | Client Sample ID | Certification | Qual | RL  | Result          | Units | DF | Date Analyzed    | Date Collected  |
|---|------------------|---------------|------|-----|-----------------|-------|----|------------------|-----------------|
| <b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b> |                  |               |      |     |                 |       |    |                  |                 |
| <b>Lead</b>   |                  |               |      |     |                 |       |    |                  |                 |
| 24080975-001A   | 164-MTS-12       | NELAP         |      | 1.0 | <b>4.0</b>      | µg/L  | 1  | 08/15/2024 20:49 | 08/08/2024 9:30 |
| 24080975-002A   | 164-MTS-13       | NELAP         |      | 1.0 | <b>5.3</b>      | µg/L  | 1  | 08/15/2024 21:11 | 08/08/2024 9:30 |
| 24080975-003A   | 164-MTS-05       | NELAP         |      | 1.0 | <b>3.6</b>      | µg/L  | 5  | 08/16/2024 16:03 | 08/08/2024 9:30 |
| 24080975-004A   | 165-MTS-10       | NELAP         |      | 1.0 | <b>&lt; 1.0</b> | µg/L  | 1  | 08/15/2024 21:15 | 08/08/2024 9:30 |



# Receiving Check List

<http://www.teklabinc.com/>

Client: Occu-Tec

Work Order: 24080975

Client Project: 924276 MTS

Report Date: 19-Aug-24

Carrier: Crossroads

Received By: AMD

Completed by:

*Amber Dilallo*

Reviewed by:

*Ellie Hopkins*

On:

12-Aug-24

Amber Dilallo

On:

12-Aug-24

Ellie Hopkins

Pages to follow:

Chain of custody

Extra pages included

- |   |  |                              |                                      |                                     |                          |
|---|--|------------------------------|--------------------------------------|-------------------------------------|--------------------------|
| Shipping container/cooler in good condition?            | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  | Not Present <input type="checkbox"/> | Temp °C                             | N/A                      |
| Type of thermal preservation?                           | None <input checked="" type="checkbox"/> | Ice <input type="checkbox"/> | Blue Ice <input type="checkbox"/>    | Dry Ice                             | <input type="checkbox"/> |
| Chain of custody present?                               | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |                                      |                                     |                          |
| Chain of custody signed when relinquished and received? | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |                                      |                                     |                          |
| Chain of custody agrees with sample labels?             | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |                                      |                                     |                          |
| Samples in proper container/bottle?                     | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |                                      |                                     |                          |
| Sample containers intact?                               | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |                                      |                                     |                          |
| Sufficient sample volume for indicated test?            | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |                                      |                                     |                          |
| All samples received within holding time?               | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |                                      |                                     |                          |
| Reported field parameters measured:                     | Field <input type="checkbox"/>           | Lab <input type="checkbox"/> | NA                                   | <input checked="" type="checkbox"/> |                          |
| Container/Temp Blank temperature in compliance?         | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |                                      |                                     |                          |

*When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.*

- |   |   |                             |                   |                                     |
|---|---|-----------------------------|-------------------|-------------------------------------|
| Water – at least one vial per sample has zero headspace?  | Yes <input type="checkbox"/>            | No <input type="checkbox"/> | No VOA vials      | <input checked="" type="checkbox"/> |
| Water - TOX containers have zero headspace?               | Yes <input type="checkbox"/>            | No <input type="checkbox"/> | No TOX containers | <input checked="" type="checkbox"/> |
| Water - pH acceptable upon receipt?                       | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | NA                | <input type="checkbox"/>            |
| NPDES/CWA TCN interferences checked/treated in the field? | Yes <input type="checkbox"/>            | No <input type="checkbox"/> | NA                | <input checked="" type="checkbox"/> |

**Any No responses must be detailed below or on the COC.**

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

# CHAIN OF CUSTODY

**TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005**



|   |   |
|---|---|
| Client: <u>OCCU-TEC Inc,</u><br>Address: <u>2604 NE Industrial Drive Suite 230</u><br>City/State/Zip: <u>North Kansas City, MO 64117</u><br>Contact: <u>Justin Arnold</u> Phone: <u>816-810-3276</u><br>Email: <u>jamold@occutec.com</u> Fax: <u>816-994-3478</u> | Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input checked="" type="checkbox"/> NO ICE <u>N/A</u> °C<br>Preserved in: <input checked="" type="checkbox"/> LAB <input type="checkbox"/> FIELD <u>FOR LAB USE ONLY</u><br>LAB NOTES: |
|---|---|

Client Comments:  
Pb RL <5.0 ppb

Are these samples known to be involved in litigation? If yes, a surcharge will apply:  Yes  No  
 Are these samples known to be hazardous?  Yes  No  
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section:  Yes  No

|  |  |  |                             |
|--|--|--|-----------------------------|
| PROJECT NAME/NUMBER<br><u>924274</u>   | SAMPLE COLLECTOR'S NAME<br><u>Justin Henderson</u> | # and Type of Containers   | INDICATE ANALYSIS REQUESTED |
| RESULTS REQUESTED<br><input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge)<br><input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge) |  | BILLING INSTRUCTIONS   |                             |
|  |  | UNP<br>HNO3<br>NaOH<br>H2SO4<br>HCL<br>MeOH<br>NaHSO4<br>TSP<br>Other<br>Lead by 200.8 |                             |

| Lab Use Only        | Sample ID         | Date/Time Sampled | Matrix                | UNP | HNO3 | NaOH | H2SO4 | HCL | MeOH | NaHSO4 | TSP | Other | Lead by 200.8                       |
|---------------------|-------------------|-------------------|-----------------------|-----|------|------|-------|-----|------|--------|-----|-------|-------------------------------------|
| <u>24080975-001</u> | <u>164-MTS-12</u> | <u>8/8 0930</u>   | <u>Drinking Water</u> | X   |      |      |       |     |      |        |     |       | <input checked="" type="checkbox"/> |
| <u>002</u>          | <u>164-MTS-13</u> | ↓                 | <u>Drinking Water</u> | X   |      |      |       |     |      |        |     |       | <input checked="" type="checkbox"/> |
| <u>003</u>          | <u>164-MTS-05</u> | ↓                 | <u>Drinking Water</u> | X   |      |      |       |     |      |        |     |       | <input checked="" type="checkbox"/> |
| <u>004</u>          | <u>165-MTS-10</u> | ↓                 | <u>Drinking Water</u> | X   |      |      |       |     |      |        |     |       | <input checked="" type="checkbox"/> |
|                     |                   |                   | <u>Drinking Water</u> | X   |      |      |       |     |      |        |     |       | <input checked="" type="checkbox"/> |
|                     |                   |                   | <u>Drinking Water</u> | X   |      |      |       |     |      |        |     |       | <input checked="" type="checkbox"/> |
|                     |                   |                   | <u>Drinking Water</u> | X   |      |      |       |     |      |        |     |       | <input checked="" type="checkbox"/> |
|                     |                   |                   | <u>Drinking Water</u> | X   |      |      |       |     |      |        |     |       | <input checked="" type="checkbox"/> |
|                     |                   |                   | <u>Drinking Water</u> | X   |      |      |       |     |      |        |     |       | <input checked="" type="checkbox"/> |
|                     |                   |                   | <u>Drinking Water</u> | X   |      |      |       |     |      |        |     |       | <input checked="" type="checkbox"/> |
|                     |                   |                   | <u>Drinking Water</u> | X   |      |      |       |     |      |        |     |       | <input checked="" type="checkbox"/> |

| Relinquished By   | Date/Time           | Received By   | Date/Time           |
|---|---------------------|---|---------------------|
|  | <u>8/8 1600</u>     |  | <u>8/9/24 1117</u>  |
| <u>J. Cole</u>  | <u>8-10-24 1327</u> | <u>Amber O'Connell</u>  | <u>8-10-24 1250</u> |
|   |                     |   | <u>8/15/24 1327</u> |

\*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.teklabinc.com](http://www.teklabinc.com) for terms and conditions